

Annual Maintenance Check of Exchange Power, Ringing, Alarms

Norchard

Year

--	--	--	--	--

Check safety aspects of installation

--	--	--	--	--

Run with mains off for one hour

--	--	--	--	--

Battery check (terminals, visual & voltage)

--	--	--	--	--

Main & standby PU check

--	--	--	--	--

Check and lubricate ringer

--	--	--	--	--

Check alarms and alarm extension

--	--	--	--	--

Check equipment clean and tidy

--	--	--	--	--

--	--	--	--	--

--	--	--	--	--

Date inspection & maintenance completed

--	--	--	--	--

Inspecting Officer's Initials

--	--	--	--	--

Comments Box below